



PIPE DIA. Inches	Bd TRENCH WIDTH TOP OF PIPE Feet
4"	2.00
6	2.00
8	2.33
10	2.50
12	2.67
15	3.00
18	3.25
21	3.54
24	3.83
27	4.08
30	4.42
33	4.75
36	5.67
42	6.25
48	6.83
54	7.42
60	8.00
66	8.58
72	9.17
78	9.75
84	10.33

Bd-Maximum Trench Width at 12" above top of Pipe if Ditch is cut wider than Bd shown the contractor will be required to increase bedding to compensate for additional load on pipe at his own expense.

200-30

WATER LINE DETAILS FOR PVC PIPE
(TRAVELED AREA OUTSIDE CITY LIMITS) & D.I. PIPE 200-30