



SEWAGE AIR RELEASE VALVE  
NO SCALE

NOTES:

1. WHERE SEWER LINES CROSS IMPROVED, GRASSED, OR LAWN AREAS, ECT. ALL SOD, SRUBS, FLOWERS, PLANTINGS, ECT., SHALL BE REPLACED IN ORIGINAL CONDITION AT CONTRACTORS EXPENCE. GRASSED AREAS SHALL BE RESTORED TO PRIOR CONDITIONS IN THE FOLLOWING MANNER  
AREAS LESS THAN 3:1 SLOPE SHALL BE RESEEDED AND MULCHED WITH GRASSES OR GROUND COVER AS OUTLINE IN THE SPECIFICATIONS. AREAS GREATER THAN 3:1 SLOPE SHALL BE RESEEDED AND MULCHED WITH A FIBROUS MATERIAL AS OUTLINE IN THE SPECIFICATIONS. PAYMENT SHALL BE INCLUDED IN THE APPLICATION UNIT PRICE BID FOR THE SEWER LINE.
2. WHERE LINES CROSS UNDER CURBS, THEY SHALL BE TUNNELED UNDER THE CURB. NO SEPARATE PAYMENT WILL BE ALLOWED FOR REPAIRING CURBS DAMAGED OR DESTROYED DURING SEWERLINE CONSTRUCTION.
3. PROMISCUOUS DESTRUCTION OF TREES ALONG SEWER LINE RIGHT-OF-WAY WILL NOT BE PERMITTED ALL REASONABLE EFFORTS WILL BE MADE BY THE CONTRACTOR TO PROTECT AND SAFEGUARD TREES.
4. ANY EXSISTING FENCES, ROCK WALLS, GUARDRAILS, ECT., ALONG THE SEWER LINE RIGHT-OF-WAY ARE TO BE REMOVED AND REINSTALLED IN THEIR ORIGINAL CONDITION (OR BETTER) NO SEPARATE PAYMENT WILL BE ALLOWED. PAYMENT TO BE BID THE APPLICABLE UNIT PRICE BID FOR THE SEWER LINE.
5. ALL FORCE MAIN LINES SHALL HAVE A MINIMUM COVER OF 30 INCHES, EXCEPT AS OTHERWISE NOTED.
6. THE COST FOR DIVERSION OF WATER IN DITCHES, CREEKS, OR RIVERS SHALL BE INCLUDED IN THE APPLICATION UNIT PRICE BID FOR SEWER LINE IN THE BID SCHEDULE. NO SEPARATE PAYMENT SHALL BE ALLOWED.
7. WHEN BLASTING FOR EXCAVATION OF WORK ADEQUATE PRECAUTION SHALL BE USED TO PREVENT DAMAGE TO SURROUNDING PROPERTY.